

EAST CONTRA COSTA FIRE PROTECTION DISTRICT

BATTALION CHIEF'S MAJOR INCIDENT SUMMARY



DATE: 7/23/2017 **TIME:** 16:18 hrs **INCIDENT NUMBER:** 17071531

TYPE OF INCIDENT: Kitchen Fire- Commercial Fire response

LOCATION: 150 Cortona Way, Brentwood CA

OWNER OR OCCUPANTS' NAME: Cortona Senior Living - multiple residents

RESPONDING COMPANIES: E88, E53, E1695, E81, E82, BC8, 5114, BC5, AMR, EMS8, EMS2, PG&E, BPD

NUMBER OF FIREFIGHTERS: Nineteen (19)

CONDITIONS ON ARRIVAL: Small fire behind the stove in the kitchen area. Residents evacuated to front courtyard. Brentwood PD assisted with resident evacuation.

ACTIONS TAKEN TO CONTROL INCIDENT: BC8 arrived and established "Cortona IC". E88 and E53 entered building and extinguished the fire with dry chemical extinguishers, E88 crew also manually pulled the fire suppression system above the stove. BC8 requested three(3) code two ambulances precautionary for the residents who were in the heat outside. Once fire was out all residents were let back into building.

DESCRIPTION OF DAMAGE: Damage to stove and cooking area. Damage was confined to that area

ESTIMATED MONETARY LOSS: N/A

INJURIES TO CIVILIANS OR FIREFIGHTERS: No civilian injuries. No firefighter injuries.

PROBABLE CAUSE: Possible grease fire in stove area.

REPORTING CHIEF OFFICER: Interim Battalion Chief Ross Macumber